


Section A-A



Section B-B

General Notes

Materials:

- Cement - CSA A5 Type HS
- Concrete Strength at 28 days - 30 Mpa
- Air Entrainment - 5-8%
- Aggregate Size ( max) - 20mm
- Made to CSA A257.4 Standard
- Conforms to A.S.T.M. C478 Standard
- Reinforcing steel Yield Strength - 400 Mpa
- All Dimensions in Inches unless otherwise indicated
- All Rubber gasket material supplied by Pre-Con certified to ASTM C923

No.	Revision/Issue	Date

**Pre-Con Ltd**  
 3320 Idylwyld Dr. North  
 Saskatoon SK  
 Phone 306-931-9229

Project Tarnes Electric  
 Transformer Base

Date April 06, 2015

Drawn by:  
 Gerry Esau A.Sc.T.

Sheet  
**1/1**

Scale **NTS**